

ഭരണഭാഷ - മാതൃഭാഷ

പ്രിൻസിപ്പൽ ഡയറക്ടറേറ്റ്, തദ്ദേശസ്വയംഭരണ വകുപ്പ്

സ്വരാജ് ഭവൻ, നന്തൻകോട്, കവടിയാർ പി.ഒ

തിരുവനന്തപുരം-695003, ഫോൺ: 0471-2727255, 2314526

വെബ്സൈറ്റ്: principaldirectorate.lsgkerala.gov.in

ഇ-മെയിൽ: pd.lsgd@kerala.gov.in



നമ്പർ: LSGD/PD/10786/2024-DB1

തീയതി: 13-03-2024

സർക്കുലർ

വിഷയം: ത.സ്വ.ഭ.വ.- പ്രിൻസിപ്പൽ ഡയറക്ടറേറ്റ് - പ്രീകാസ്റ്റ് കോൺട്രിറ്റ് പേവർ ബ്ലോക്കുകൾക്കായുള്ള ക്വാളിറ്റി കൺട്രോൾ ടെസ്റ്റുകൾ- സംബന്ധിച്ച്

- സൂചന:
1. Letter No. InspTech-2/33/2024-FIN dated 22-02-2024 of Finance(Inspection Wing-Techr Department
 2. Circular No. 31/2022-Fin dated 06.04.2022 of the Finance(Inspection Wing - Technical) Department .

മേൽ വിഷയത്തിലേക്കും സൂചനയിലേക്കും ശ്രദ്ധ ക്ഷണിക്കുന്നു. ധനകാര്യ (ഇൻസ്പെക്ഷൻ വിംഗ്-ടെക്നിക്കൽ) വകുപ്പിലെ ഉദ്യോഗസ്ഥരുടെ വിവിധ സ്ഥല പരിശോധനകളിൽ, IS 15658:2006-ൽ അനുശാസിക്കുന്ന എല്ലാ നിർബന്ധിത ഗുണനിലവാര നിയന്ത്രണ പരിശോധനകളും വിവിധ പ്രവൃത്തികൾക്കായി ഉപയോഗിക്കുന്ന പ്രീകാസ്റ്റ് കോൺട്രിറ്റ് പേവർ ബ്ലോക്കുകൾക്കായി നടത്തുന്നില്ലെന്ന് ശ്രദ്ധയിൽപ്പെട്ടിട്ടുണ്ടെന്ന് സൂചന (1) പ്രകാരം അറിയിച്ചിരിക്കുന്നു. ടി സാഹചര്യത്തിൽ പ്രീകാസ്റ്റ് കോൺട്രിറ്റ് പേവർ ബ്ലോക്കുകൾക്കായി IS 15658:2006-ൽ അനുശാസിക്കുന്ന പ്രകാരവും സൂചന (2) സർക്കുലർ പ്രകാരവും എല്ലാ നിർബന്ധിത ഗുണനിലവാര നിയന്ത്രണ പരിശോധനകളും നടക്കുന്നുണ്ടെന്ന് ഉറപ്പാക്കേണ്ടതാണ്.


Signed by വിശ്വസ്തയോടെ,
 Sandeep K G Sandeep K G
 Date: 13-03-2024 19:03:09 CHIEF ENGINEER

ഉള്ളടക്കം : 1. സൂചന (2) സർക്കുലർ

DM



4525
19/04/2022



GOVERNMENT OF KERALA
Finance (Inspection Wing-Technical) Department

CIRCULAR

No.31/2022-Fin

Thiruvananthapuram
Dated : 06.04.2022

Sub :- Use of precast Concrete Paver Blocks for public works in the state -
Ensuring the quality and standard specifications Directions issued -
Regarding.

Ref :- Stipulations in the IS Code No. 15658:2006.

During the various site inspections conducted by the officials from this Wing, it is observed that required specifications were not ensured and obligatory quality tests as stipulated in "IS 15658:2006 for Precast Concrete Blocks for paving - Specifications" were not being conducted by the certain field units in the case or road construction, Yard, Footpaths, etc. which can affect the durability of such constructions:-

The Government after having examined the case are pleased to issue the following directions for strict compliance:-

1. The Technical Sanction and Agreement authorities shall ensure that the Specifications for Precast Concrete Paver blocks proposed/used for all public works shall conform to the standards set by the Bureau of Indian Standards (IS 15658:2006).
2. The Engineer-In-Charge of work shall ensure that all obligatory quality control tests are conducted for the Precast Concrete Blocks used for the work as stipulated in the above IS Code.
3. Defect Liability Period of the roads, yards, footpaths, etc. constructed using the Precast Concrete Paver blocks shall be not be less than 5 years.

Hari Kumar.S.
Chief Technical Examiner &
Ex-Officio Secretary to Government.

9
8/4/22
To

1. The Principal Accountant General (A&E), Kerala, Thiruvananthapuram.
2. The Additional Chief Secretary (Finance) & Secretary (FE).
3. All Additional Chief Secretaries/Principal Secretaries/ Secretaries to Government.
4. The Additional Secretary to Chief Secretary.
5. The Chief Executive Officer, KIIFB, Thiruvananthapuram.
6. The Chairman and Managing Director, KSEBL, Thiruvananthapuram.
7. The Managing Director, KWA, Thiruvananthapuram.
8. All Chief Engineers, PWD/WRD/LSGD/HED. *TVPM-33*
9. The Managing Director, RBDC/KRFB/KSCC.
10. The Director, Public Relations, Thiruvananthapuram for wide publicity.
11. The Nodal Officer, www.finance.kerala.gov.in - for publishing in the official web site of Finance Department & Government of Kerala.

Forwarded /By Order

Accounts Officer