



2.6.18

GOVERNMENT OF KERALA

No.Insp-Tech-2/36/2018-FIN

Finance(Inspection -Technical -Wing) Dept.,
SBTEU Building, Pulimoodu,
Thiruvananthapuram - 695 001,
Dated: 07/05/2018.

From
The Chief Technical Examiner.

To
The Chief Engineer (LSGD),
Swaraj Bhavan, Nandancode,
Thiruvananthapuram - 695 033.

Rural Roads Development Agency
695 033
14 MAY 2018
M-695 003

missent
To
CE LSGD

Sir,

Sub:- Recording of levels for laying of WMM - Exemption requested -Reg.

Ref:- Your letter No. DB1/2788/2018/CE/LSGD dated 27/03/2018.

DB1

14/5/18

Please refer to the above. For assessing the quantity of works done in respect of WMM and to ensure the same at site, taking the initial and final levels of road are necessary.

Therefore, waiver of the stipulation of taking the initial and final levels for assessing the quantity of WMM less than 100m³ is not advisable.

Yours faithfully,

V.M. SURENDRAN
V.M. SURENDRAN,
Chief Technical Examiner In Charge.